

DX 342

Multi Function Counters with 2 Presets,
2 Relay Outputs and Serial RS 232 / RS 485 Interface



Operating Modes:

- High Speed Counter for Positions and Events (100 kHz)
- Tachometer, Frequency Meter
- Baking Time and Processing Time Indicator (reciprocal speed)
- Timer, Stopwatch
- Speed Display from Transition Time between Start and Stop Impulse
- Additional Functions: Linearization, Brightness Control, Digital Filter etc.

Operating Instructions



Safety Instructions

- This manual is an essential part of the unit and contains important hints about function, correct handling and commissioning. Non-observance can result in damage to the unit or the machine or even in injury to persons using the equipment!
- The unit must only be installed, connected and activated by a qualified electrician
- It is a must to observe all general and also all country-specific and application-specific safety standards
- When this unit is used with applications where failure or maloperation could cause damage to a machine or hazard to the operating staff, it is indispensable to meet effective precautions in order to avoid such consequences
- Regarding installation, wiring, environmental conditions, screening of cables and earthing, you must follow the general standards of industrial automation industry *)
- - Errors and omissions excepted –



*) For General EMC Rules for Wiring, Screening and Earthing please visit the DOWNLOAD section of <http://www.motrona.com>


Version:	Description
DX34209a/hk/kk/Dec.09	First edition

Table of Contents


1.	Electrical Connections.....	4
1.1.	Power Supply	4
1.2.	Aux. Voltage Output	5
1.3.	Inputs A, B and Reset.....	5
1.4.	Relay Outputs	6
1.5.	The Serial RS232 / RS485 interface	6
2.	How to Operate the Front Keys.....	7
2.1.	Normal Display State	7
2.2.	Selection and Setting of Parameters	8
2.2.1.	How to select a parameter.....	8
2.2.2.	How to change parameter settings.....	8
2.2.3.	How to store settings.....	8
2.2.4.	Time-Out Function	8
2.3.	Teach Operation	9
2.4.	Set All Registers to "Default"	9
2.5.	Code Locking of the Keypad.....	9
3.	The Operator Menu.....	10
3.1.	Overview of Basic Parameters	10
3.2.	Overview of Operational Parameters.....	11
4.	Setup Procedure.....	12
4.1.	Basic Settings	12
4.2.	Operational Parameters.....	14
4.2.1.	RPM, operation as tachometer or frequency counter	14
4.2.2.	Time, display of baking or processing time (reciprocal speed).....	15
4.2.3.	Timer, Stopwatch	16
4.2.4.	Count, Counter mode.....	17
4.2.5.	Speed from differential time between a Start and a Stop input.....	19
4.2.6.	Linearization points	19
4.3.	Additional Settings for the Preselections	20
4.4.	Additional Settings for the Serial Interface.....	22
4.4.1.	PC-Mode	24
4.4.2.	Printer-Mode.....	26
5.	Special Functions.....	27
5.1.	Linearization	27
5.2.	Manual Input or „Teaching“ of the Interpolation Points	29
6.	Technical Appendix.....	31
6.1.	Dimensions	31
6.2.	Technical Specifications.....	32
6.3.	Parameter-List	33
6.3.1.	General	33
6.3.2.	Linearization	34
6.3.3.	Preselections	35
6.3.4.	Serial interface	35
6.4.	Commissioning Form	36

1. Electrical Connections

Terminal Assignments and Example of Wiring



Special versions with TTL inputs (option TTLIN1) provide an auxiliary output of +5 volts instead of +24 volts on terminal 7.



*) Contact positions are shown in powerless state

1.1. Power Supply

The unit accepts DC power supply from 17 V to 30 V via screw terminals 1 and 2. The consumption depends on the level of the supply voltage (typically between 80 mA and 150 mA plus current taken from the auxiliary output).

1.2. Aux. Voltage Output

Terminal 7 provides an auxiliary output of 24 VDC / 120 mA max. for supply of sensors and encoders. Units with TTL inputs (option TTLIN1) provide a 5 VDC / 120 mA auxiliary output on terminal 7 instead.

1.3. Inputs A, B and Reset

In the basic setup menu these inputs can be configured to PNP (switch to +) or to NPN (switch to -). This configuration is valid for all three inputs at a time.



The factory setting is always PNP.

With standard units the input level is always HTL (Low <2.0 V and High >9.0 V)

Units equipped with option TTLIN1 provide TTL / CMOS level (Low <0.8 V and High >3.5 V)



- Independent of your setting, all functions of the unit are "active HIGH" and the unit triggers to positive transitions (rising edge).
- With NPN setting please be aware that an open or unused RESET input is HIGH. Therefore the unit will be kept in a continuous RESET state and will not work, unless you tie the Reset line to GND (terminal 1 or 6)
- Where you use 2-wire NAMUR type sensors, please select NPN, connect the negative wire of the sensor to GND and the positive wire to the corresponding input.



Typical input circuit (standard version with HTL inputs):

The counting inputs A and B are designed for input frequencies up to 100 kHz (with all counter modes) and up to 25 kHz (with all other operating modes).

The minimum pulse duration on the Reset input must be 500 µsec. (maximum frequency 1 kHz)

All inputs are designed to receive impulses from an electronic impulse source. Where exceptionally you need to **use mechanical contacts**, please connect an external capacitor between GND (-) and the corresponding input (+). With a capacity of 10 µF, the maximum input frequency will reduce to 20 Hz and miscounting due to contact bouncing will be eliminated.


1.4. Relay Outputs

Both relays provide individually programmable switching characteristics. It is strictly recommended to use additional external filtering components when switching inductive loads. The switching capability of the relays is 250 VAC / 1 A / 250 VA or 100 VDC / 1 A / 100 W

The response delay of the relays is by 10 msec. approximately.

1.5. The Serial RS232 / RS485 interface


Ex factory the unit is set to RS232 communication. This setting can be changed to RS485 (2-wire) by means of an internal DIL switch. To access the DIL switch, please remove the screw terminal connectors and the backplane. Then pull the print to the rear to remove the PCB from the housing.



- Never set DIL switch positions 1 and 2 or DIL switch positions 3 and 4 to ON at the same time!
- After setting the switch, shift the print carefully back to the housing, in order to avoid damage of the front pins for connection with the front plate.

2. How to Operate the Front Keys

For setup and other operations the unit uses three front keys which subsequently will be denominated as follows:




The functions of the keys are depending on the actual operating state of the unit.

The following three operating states apply:

- **Normal display state**
- **Setup state**
 - a.) Basic setup
 - b.) Operational parameter setup
- **Teach operation**

2.1. Normal Display State



Change over to	Key operation
Basic setup	Keep ENTER and SET down simultaneously for 3 seconds
Operational parameter setup	Keep ENTER down for 3 seconds.
Teach operation	Keep Cmd down for 3 seconds

The Cmd key is only used to execute the Teach procedure with linearization. For more details please refer to sections 5.1 and 5.2.

2.2. Selection and Setting of Parameters

2.2.1. How to select a parameter

The **ENTER** key will scroll through the menu. The **SET** key allows to select the corresponding item and to change the setting or the numeric value. After this, the selection can be stored by **ENTER** again, which automatically changes over to the next menu item.

2.2.2. How to change parameter settings

With numerical entries, at first the lowest digit will blink. When keeping the **SET** key continuously down, the highlighted digit will scroll in a continuous loop from 0 ... 9 , 0 ... 9. After releasing the **SET** key, the actual value will remain and the next digit will be highlighted (blink). This procedure allows setting of all digits to the desired values. After the most significant digit has been set, the low order digit will blink again and you can do corrections if necessary.

With signed parameters, the high order digit will scroll from "0" to "9" (positive) followed by "-" and "-1" (negative)

2.2.3. How to store settings

To store the actual setting, press the **ENTER** key, which will also automatically scroll forward the menu.

At any time the unit changes from programming mode to normal display operation, when you keep the **ENTER** key down again for at least 3 seconds.

2.2.4. Time-Out Function

A "time-out" function will automatically conclude every menu level, when for a break period of 10 seconds no key has been touched. In this case, all changes which have not been confirmed by **ENTER** yet would remain unconsidered.

2.3. Teach Operation



The Time-Out Function remains disabled during all Teach operations

Key	Function
	ENTER will conclude or abort any Teach operation in progress
	SET function is fully similar to normal set-up operation
	Cmd will store the display value to the register and will change over to the next interpolation point.

For details of the Teach procedure see section 5.2.

2.4. Set All Registers to “Default”

At any time you can return all settings to the factory default values.



This action will reset all parameters to factory default values and your own settings will be lost. You will have to repeat your individual setup procedure. Factory default values are shown in the subsequent parameter tables.

To reset the unit to default values:

- switch power off
- press the **ENTER** key on the front
- keep **ENTER** down while you power up again

2.5. Code Locking of the Keypad

When the code locking of the keypad has been switched on, any key access first results in display of



To access the menu you must press the key sequence



within 10 seconds, otherwise the unit will automatically return to the normal display mode.

3. The Operator Menu

The menu provides one section with "Basic Parameters" and another section with "Operational Parameters". On the display you will only find those parameters which have been enabled by the basic settings. E.g. when the Linearisation Function has been disabled in the basic set-up, the associated linearization parameters will also not appear in the parameter menu.

All parameters, as good as possible, are designated by text fragments. Even though the possibilities of forming texts are very limited with a 7-segment display, this method has proved to be most suitable for simplification of the programming procedure.

The subsequent table shows the general structure of the menu.
Detailed descriptions of all parameters will follow in section 4.

3.1. Overview of Basic Parameters

General:	Type (Application Mode) Input Characteristics Brightness Code Linearization Mode *)
Preselections:	Preselection Mode 1 Preselection Mode 2 Hysteresis 1 Hysteresis 2
Serial Interface:	Serial Unit Number Serial Format Serial Baud Rate

*) Appears only with Modes "RPM" and "Count"

3.2. Overview of Operational Parameters

	Mode "RPM" (Tachometer)	Mode "Time" (Baking Time)	Mode "Timer" (Stopwatch)	Mode "Count" (Counter)	Mode "Speed" (Transition speed)
Preselections			Preselection 1 Preselection 2		
Display and Scaling:	Frequency Display Value Decimal Point Wait Time Average Filter	Display Format Frequency Decimal Value Wait Time Average Filer	Base (Resolution) Start/Stop Auto Reset Latch Function	Counter Mode Scaling Factor Set Value Reset/Set Decimal Point	Time Display Value Decimal Point Wait Time
Serial Interface:			Serial Timer Serial Mode Serial Code		
Linearization	P01_H *) P01_Y *) .. P16_H *) P16_Y *)			P01_H *) P01_Y *) .. P16_H *) P16_Y *)	

*) Appears only with modes "RPM" and "Count" when the linearization function has been enabled

4. Setup Procedure

For better understanding the following sections 4.1 and 4.2 explain settings related to the display only. Additional settings related to Preselections and Serial Link will be explained separately, later.

4.1. Basic Settings

These settings in general have to be carried out one time only upon the very first use of the unit. The basic setup selects the desired operation mode of the unit, the input characteristics PNP/NPN and the desired brightness of the LED display.



To access the Basic Setup press ENTER and SET simultaneously for at least 3 seconds.

Menu	Setting Range	Default
TYPE	Operation Mode: Tachometer, frequency meter (4.2.1) Baking time / processing time indicator (4.2.2) Timer, Stopwatch (4.2.3) Counter for position or event (4.2.4) Speed calculation from differential transition time (4.2.5)	rPnD t, nE t, nEg Count SPEED
CHAR	Switching characteristics of the inputs: NPN, switch to “-“ PNP, switch to “+“	PnP
bright	Brightness of the LED display: 20%, 40%, 60%, 80%, 100%	100%

Menu		Setting Range	Default
Code	<p>Keypad protection code:</p> <p>Keypad enabled continuously</p> <p>Keypad locked for any access</p> <p>Keypad locked, except for access to preselections Pres 1 und Pres 2</p>	<input type="button" value="no"/> <input type="button" value="ALL"/> <input type="button" value="P_FrEE"/>	<input type="button" value="no"/>
Linear	<p>Linearization Mode: *)</p> <p>For details please refer to 5.1 and 5.2</p> <p>The linearization is switch off.</p> <p>Linearization settings for the positive range only (negative values will appear as a mirror).</p> <p>Linearization over the full numeric range</p>	<input type="button" value="no"/> <input type="button" value="1-9UR"/> <input type="button" value="4-9UR"/>	<input type="button" value="no"/>

*) appears with Tachometer mode and Counter mode only

4.2. Operational Parameters


4.2.1. RPM, operation as tachometer or frequency counter

(Input A = frequency input, Input B not in use)

Menu		Setting Range	Default
 FrEq.	Frequency: Set a typical operating frequency for your application.	1 Hz to 25 000 Hz	1000
 d.SPL	Display Value: Set the value you would like to see on your display with above frequency at the input.	1 ... 99999	1000
 dPo int	Decimal Point: Select the desired position like shown in the display. no decimal point decimal point at position 1 ----> decimal point at position 5	000000 00000.0 0.00000	000.000
 Wait	Wait Time: Define a "waiting time", this is the time in seconds that the unit will wait from one input pulse to the next, before it sets the display to zero. When you enter "0", the unit will wait forever and show the last result until it receives the next input.  The setting of this parameter automatically limits the minimum input frequency correspondingly. With "Wait" set to e.g. 0.1 sec. the unit will respond to frequencies > 10 Hz only and all lower frequencies will just display 0.	0.1 ... 99.9 sec	1.0
 Filter	Average Filter: Selectable average filter to suppress unstable display with unsteady input frequencies. No filtering 2, 4, 8, 16 = number of floating average cycles.	 	

4.2.2. Time, display of baking or processing time (reciprocal speed)

(Input A = frequency input, Input B not in use)

Menu		Setting Range	Default
d ,SFor	Display Format: Select between seconds, minutes, minutes and seconds or minutes with two decimal positions. This will also automatically set your decimal point to the proper place. Seconds Minutes Minutes and seconds Minutes with two decimal positions	   	SEC
FrEq_u	Frequency: Set a typical operating frequency for your application.	1 Hz to 25 000 Hz	100
d ,SPL	Display Value: Set the value you would like to see on your display with above frequency at the input.	1 ... 999999	100
LJA .t	Wait Time: Define a "waiting time", this is the time in seconds that the unit will wait from one input pulse to the next, before it sets the display to zero. When you enter "0", the unit will wait forever and show the last result until it receives the next input.  The setting of this parameter automatically limits the minimum input frequency correspondingly. With "Wait" set to e.g. 0.1 sec. the unit will respond to frequencies > 10 Hz only and all lower frequencies will just display 0.	0.1 ... 99.9 s	5.0
F ILTEr	Average Filter Selectable averages filter to suppress unstable display with unsteady input frequencies. No filtering 2, 4, 8, 16 = number of floating average cycles.	 	OFF

4.2.3. Timer, Stopwatch

Please note that open NPN inputs are always "HIGH" and open PNP inputs are always "LOW".

Menu		Setting Range	Default
base	Time base / Resolution of the timer:	SEC000 SEC00 SECO SEC 0.0..00 0.0..0 H-mm-S	SEC000
start	Start/Stop of time measurement: Time count is active while input A is HIGH. Rising edge on input A starts count. Rising edge on input B stops count. Period time measurement. Repeating display of the time between two rising edges on input A	H..Loo St..SP A_StSP	St..SP
reset	Auto Reset: Time count cumulates with every new start. No automatic Reset. Use the Reset input to set to zero. Every start initializes a new count starting from zero.	no yes	no
latch	Latch Function: Real time display, count visible. Frozen display of the final count result after every Stop. The timer counts in the background,	no yes	no

4.2.4. Count, Counter mode

Menu		Setting Range	Default
Count	Counting Mode: Input A counts and input B selects the counting direction (LOW = increment, HIGH = decrement) Summing counter, A + B Differential counter, A – B Quadrature up/down counter A/B with single edge count (x1) Quadrature up/down counter A/B with double edge count (x2) Quadrature up/down counter A/B with (x4) edge count.	A_bd sr A_u b A - b A_b .1 A_b 2 A_b 4	A_b .1
Factor	Impulse Scaling Factor: Example: setting 1.2345 results in display of 12 345 after 10 000 input pulses.	0.0001 ... 9.9999	1.0000
Set	Set Value: Every Reset signal will set the display to the value entered here	-199 999 ... 999 999	0
Reset	Reset/Set Enable: No setting or resetting of the counter is possible Set / Reset by the front SET key Set / Reset by remote signal to the Reset input. Set / Reset by front SET key and by external input.	no Front E_tErt Fr_u_E	Fr_u_E
dPo int	Decimal Point: Select the desired position like shown in the display. no decimal point one decimal position ----> five decimal positions	000.000 00000 00000.0 0.00000	000.000



- The counting range of the unit is limited from -199999 to 999999.
In case of underflow or overflow the unit will display 
- The counter stores all counting data also in power-down state
(EEPROM with data retention >10 years)
- With the summing mode (A+B) and the differential mode (A-B) please note that the impulse scaling factor will only affect input A and input B will be scaled with a fixed factor of 1.0000

4.2.5. Speed from differential time between a Start and a Stop input

Input A operates as a start input and input B operates as a Stop input. The differential time between start and stop will be converted into the speed of the passing object.

Menu		Setting Range	Default
 Time:	Enter a typical delay time which you expect between the start and stop signals.	000.001 ... 999.999 sec	1.000 sec
 Display Value:	Enter the speed you would like to see in the display when an object passes within above time.	000.001 ... 999.999	1.000
 Decimal Point:	Select the desired position like shown in the display. no decimal point done decimal position ----> five decimal positions	000000 00000.0 0.00000	000.000
 Wait Time	How long should the last result remain in the display before it returns to zero? Set the desired waiting time. With setting "0" the display will freeze and wait until to the next measuring cycle.	0.00 ... 9.99	1.00

4.2.6. Linearization points

The linearization points will only appear with Operation Modes "RPM" or "Count" when Linearization is enabled.

Menu		Setting Range	Default
P01_X	Linearization point 1: X value of the first interpolation point.	-199999 ... 999999	999999
P01_Y	Linearization point 1: Y value of the first interpolation point.	-199999 ... 999999	999999
	
P16_X	Linearization point 16: X value of the 16. interpolation point.	-199999 ... 999999	999999
P16_Y	Linearization point 16: Y value of the 16. interpolation point.	-199999 ... 999999	999999

For more details about linearization please refer to section 5.

4.3. Additional Settings for the Preselections

The basic setup menu provides the following additional parameters:

Menu		Default
CHAR 1	Switching characteristics of output 1.	_R GE
_R GE	Greater/Equal: output to switch statically "ON" when display value \geq preset value.	
_R LE	Lower/Equal: output to switch statically "ON" when display value \leq preset value.	
_N GE	Greater/Equal: output to switch dynamically "ON" when display value \geq preset value. (timed pulse output *)	
_N LE	Lower/Equal: output to switch dynamically "ON" when display value \leq preset value. (timed pulse output *)	
JLRES	Reset: Timed impulse output *) and automatic Reset to zero when the display value reaches Preset 1.	
_N SET	Set: Timed impulse output *) and automatic setting to preset 1 when the display value reaches zero.	
CHAR 2	Switching characteristics of output 2.	_R GE
_R GE	See Char 1	
_R LE	See Char 1	
_N GE	See Char 1	
_N LE	See Char 1	
_J^- I-2	Output switches statically ON when display value \geq Preset 1 – Preset 2 **).	
_N I-2	Output switches dynamically ON when display value \geq Preset 1 – Preset 2 **).	
HYSt 1	Hysteresis 1: Adjustable hysteresis for output 1. ***) Setting range 0 ... 99999 display units	0
HYSt 2	Hysteresis 2: Adjustable hysteresis for output 2, ***) Setting range 0 ... 99999 display units	0

*) Fixed pulse duration of 500 msec (factory adjustable only)


**) This feature serves for generation of an anticipation signal with a fixed distance to the preset 1 signal. The anticipation automatically follows the setting of preset 1 (trailing preset).

***) Switching hysteresis is only active with "RPM" and "Time" operation

The following operational parameters provide setting of the switching points:

Menu	Setting Range	Default
PrES_1 Preselection 1:	-199999... 999999	10000
PrES_2 Preselection 2:	-199999... 999999	5000

The working direction of the Hysteresis depends on the setting of the switching characteristics. With settings „GE“ or „LE“ respectively, the following switch points will result:



It is possible to check up on the actual switching state of the outputs at any time.

For this, just tap on the ENTER key shortly.

The display will then show for the next two seconds one of the following information:

Display	Meaning
1_2off	Both outputs are actually off.
1_2on	Both outputs are actually on.
1 on	Output 1 is on. Output 2 is off.
2on	Output 1 is off. Output 2 is on.

4.4. Additional Settings for the Serial Interface

The basic setup menu contains the main parameters for configuration of the serial interface

Menu		Setting Range	Default
S-Un it	Serial Unit Number: You can assign any address number between 11 and 99 to your unit. The address must <u>not</u> contain a "0" because these numbers are reserved for collective addressing.	0 ... 99	11
S-Form	Serial data format: The first character indicates the number of Data Bits. The second character specifies the Parity Bit ("even" or "odd" or "none") The third character indicates the number of Stop Bits.	7 E 1 7 E 2 7 O 1 7 O 2 7 no 1 7 no 2 8 E 1 8 O 1 8 no 1 8 no 2	7 E 1
S-baud	Baud Rate: The adjoining Baud rates can be selected	9600 4800 2400 1200 600 19200 38400	9600

The following operational parameters provide setting of the communication profile:

Menu	Setting Range	Default																
S-Timer Serial Timer: Setting 0,000 allows manual activation of a serial data transmission at any time. All other settings specify the cycle time for automatic transmission (provided the Serial Mode is set to "Printer") Between two transmission cycles the unit will allow a pause depending on the baud rate. The minimum cycle times for timer transmissions are shown in the table. <table> <thead> <tr> <th>Baud Rate</th><th>Minimum Cycle Time [msec]</th></tr> </thead> <tbody> <tr> <td>600</td><td>384</td></tr> <tr> <td>1200</td><td>192</td></tr> <tr> <td>2400</td><td>96</td></tr> <tr> <td>4800</td><td>48</td></tr> <tr> <td>9600</td><td>24</td></tr> <tr> <td>19200</td><td>12</td></tr> <tr> <td>38400</td><td>6</td></tr> </tbody> </table>	Baud Rate	Minimum Cycle Time [msec]	600	384	1200	192	2400	96	4800	48	9600	24	19200	12	38400	6	0.000; 0.010... 9..999 sec	0.1 sec
Baud Rate	Minimum Cycle Time [msec]																	
600	384																	
1200	192																	
2400	96																	
4800	48																	
9600	24																	
19200	12																	
38400	6																	
S-Mod Serial Mode: Operation according to communication profile (see 4.5.1) Transmission of string type 1 (see 4.5.2) Transmission of string type 2 (see 4.5.2)	PC Print 1 Print 2	PC																
S-Code Serial Register-Code: Specifies the register code of the data to be transmitted. The most important register codes are the actual display value and the serial Set/Reset command code <table> <thead> <tr> <th>Register</th><th>S-Code</th><th>ASCII</th></tr> </thead> <tbody> <tr> <td>Actual display value</td><td>101</td><td>: 1</td></tr> <tr> <td>Activate SET /RESET</td><td>60</td><td>6 0</td></tr> </tbody> </table>	Register	S-Code	ASCII	Actual display value	101	: 1	Activate SET /RESET	60	6 0	100 ... 120	101							
Register	S-Code	ASCII																
Actual display value	101	: 1																
Activate SET /RESET	60	6 0																

4.4.1. PC-Mode

Communication with PC - Mode allows free readout of all parameters and registers of the unit. The subsequent example shows the details of communication for serial readout of the actual display value.

This is the general format of a serial request string :

EOT	AD1	AD2	C1	C2	ENQ
EOT = Control character (Hex 04)					
AD1 = Unit address, High Byte					
AD2 = Unit address, Low Byte					
C1 = Register code, High Byte					
C2 = Register code, Low Byte					
ENQ = Control character (Hex 05)					

Example: Request for the actual display value from unit number 11:

ASCII-Code:	EOT	1	1	:	1	ENQ
Hexadecimal:	04	31	31	3A	31	05
Binary:	0000 0100	0011 0001	0011 0001	0011 1010	0011 0001	0000 0101

Upon correct request the unit will respond as shown on the right. Leading zeros will be suppressed.

BCC represents a block check character generated from an Exclusive-OR of all characters from C1 through ETX (inclusively)

STX	C1	C2	x x x x x x x	ETX	BCC
STX = Control character (Hex 02)					
C1 = Register code, High Byte					
C2 = Register code, Low Byte					
x x x x x = Register data					
ETX = Control character (Hex 03)					
BCC = Block check character					

With incorrect request strings, the unit only responds STX C1 C2 EOT or just NAK.

Provided the actual display value of the unit would be "-180" (example), the full response of the unit would be as shown below:

ASCII	STX	:	1	-	1	8	0	ETX	BCC
Hex	02	3A	31	2D	31	38	30	03	1C
Binary	0000	0011	0011	0010	0011	0011	0011	0000	0001
	0010	1010	0001	1101	0001	1000	0000	0011	1100

Again BCC represents the block check character formed from the Exclusive-OR of all characters from C1 through ETX

Units with serial link also allow setting or resetting the counter by serial command (similar to the external input or front key function). To activate the Reset command, please write "1" to register code "60". To release the Reset command again, write "0" to the same register.

The following strings show how to set or reset a unit with unit No. 11:

Reset ON :

ASCII	EOT	AD1	AD2	STX	C1	C2	Data	ETX	BCC
Hex	04	31	31	02	36	30	31	03	34
Binary	0000 0100	0011 0001	0011 0001	0000 0010	0011 0110	0011 0000	0011 0001	0000 0011	0011 0100

Reset OFF :

ASCII	EOT	AD1	AD2	STX	C1	C2	Data	ETX	BCC
Hex	04	31	31	02	36	30	30	03	35
Binary	0000 0100	0011 0001	0011 0001	0000 0010	0011 0110	0011 0000	0011 0000	0000 0011	0011 0101

For more details about serial communication please refer to the separate document "SERPRO"

4.4.2. Printer-Mode

The Printer Mode allows cyclic or manual activation of transmissions of the specified register data. The corresponding register can be specified by means of parameter „S-Code“.

Another parameter named „S-mod“ allows selection between two different string types:

„S-mod“	Transmission String Type								
„Print1“	Space	Sign	Data					Line feed	Carriage return
		+/-	X	X	X	X	X	LF	CR
„Print2“	Sign	Data					Carriage return		
	+/-	X	X	X	X	X	X	CR	

The mode of activation of serial transmissions can be determined as follows:

Cyclic (timed) transmissions:	Set the Serial Timer to any value ≥ 0.010 sec. Select the desired string type by parameter "S-mod" After exit from the menu the timed transmissions will start automatically
Manual activation of transmissions	Set the Serial Timer to 0.000. Select the desired string type by parameter "S-mod" After exit from the menu a transmission can be activated at any time by shortly pressing the ENTER key

5. Special Functions


5.1. Linearization

This function allows converting a non-linear input signal into a linear presentation or vice-versa. There are 16 interpolation points available, which can be freely arranged over the whole measuring range in any distance. Between two points the unit automatically will interpolate straight lines.

It is advisable to set many points into areas with strong bending, and to use only a few points in areas with little bending. „Linearisation Mode“ has to be set to either „1-quA“ or „4-quA“ to enable the linearization function (see subsequent drawing).

Parameters P01_x to P16_x select 16 x-coordinates, representing the display values which the unit would normally show in the display. With parameters P01_y to P16_y you can specify, which values you would like to display instead of the corresponding _x values.



This means e.g. that the unit will replace the previous P02_x value by the new P02_y value.



*) Mirror of positive range

Application Example:

The picture below shows a Watergate where the opening is picked up by means of an incremental encoder. We would like to display the clearance of the gate "d", but the existing encoder information is proportional to the angular information φ .



5.2. Manual Input or „Teaching“ of the Interpolation Points

Interpolation points to form the linearization curve can be entered one after each other, using the same procedure as for all other numeric parameters. This means you will have to enter all parameters P01_x to P16_x and P01_y to P16_y manually by keypad.



During manual input of interpolation points the unit will not examine the settings P01_x to P16_x. Therefore the operator is responsible for observation of the constraint P01_X < P02_X < ... < P15_X < P16_X.

In most cases it should however be much more convenient to use the Teach function. For this method we have to move the encoder, step by step, from one interpolation point to the next. Every time we enter the desired display value by keypad.

How to use the Teach Function:

- Please select the desired range of linearization (see 4.1).
- Hold down the “Cmd” key for 3 seconds, until the display shows “tEACH”. Now the unit has switched over to the Teach mode. To start the teach procedure please press again “Cmd” within the next 10 seconds. The display will then show “P01_X”.
- With respect to the consistency required for linearization, all parameters from P01_X to P16_Y will first be overwritten by suitable initial values. Initial values for „P01_X“ and „P01_Y“ are -199999 and all other values will start with 999999.
- Press once more “Cmd” to display the actual encoder position. Then move the encoder to the first of the desired interpolation points
- When you read the x-value of your first interpolation point in the display, press “Cmd” again. This will automatically store the actual display value to the P01_x register. For about 1 second you will read “P01_y ” on the display, followed by the same reading again that has been stored previously
- This display value now can be edited like a regular parameter, and you can change it to the desired P01_y value
- When you read the desired P01_y value in your display, store it by pressing “Cmd” again. This will automatically cycle the display to the next interpolation point P02_x.


- Once we have reached and stored the last interpolation points P16_x/y, the routine will restart with P01_x again. You are free to double-check your settings once more or to make corrections.
- To conclude the Teach procedure, keep ENTER down for about 2 seconds. In the display you will read "StOP" for a short time, and then the unit returns to the normal operation. At the same time all linearization points have been finally stored.



- The unit will examine the constraint valid for the x-values of interpolation points. Every interpolation point must be higher than its preceding point. Where this constraint is breached, all 6 decimal points will blink automatically as a warning. Pressing the CMD key will not store the illegal value, but result in an error text "E.r.r.-L.O."
 - To exit the teach mode again, you have the following two possibilities:
 - Press the enter key for 2 seconds. On the display you will read "StOP" for a short time, and then the unit will switch back to the normal mode.
 - Just do nothing. After 10 seconds the unit will switch back to the normal mode automatically.
- In both cases the parameters of linearization P01_X to P16_Y will not change.

6. Technical Appendix

6.1. Dimensions



Panel cut out: 91 x 44 mm (3.583 x 1.732")

6.2. Technical Specifications

Power supply voltage	:	24 VDC (17 – 30 V)
Consumption (without sensor)	:	18 V = 120 mA, 24 V = 95 mA, 30 V = 80 mA (approx.)
Aux. voltage for encoder supply	:	24V DC, +/- 15%, 120 mA (5 VDC / 120 mA with option TTLIN1)
Inputs	:	3 (PNP/NPN/Namur), A/B = Impulse, C = Reset
Input currents	:	5.1 mA / 24 V (R _i = 4.7 kOhms)
Input level HTL (standard)	:	Low: 0 ... 3.5 V, High: 9 ... 30V
Input level TTL (option TTLIN1)	:	CMOS levels, Low: 0 ... 0.8 V, High: 3.6 ... 5.0 V
Max. input frequency	:	All counter modes: 100 kHz All other operating modes: 25 kHz Reset input C: 1 kHz (min. pulse duration 500 µsec)
Display update rate	:	approx. 7 msec (330 msec with tachometer operation)
Accuracy (frequency measurement)	:	+/- 1 ppm +/- 1 Digit
Serial Interface	:	RS 232 or RS 485 (switch selectable) 600 - 38400 bauds
Ambient temperature	:	Operation: 0° - 45°C (32 – 113°F) Storage: -25° - +70°C (-13 – 158°F)
Housing	:	Norly UL94 – V-0
Display	:	6 Digit, LED, high- efficiency orange, 15 mm (0.59")
Protection class	:	Front IP65, Rear IP20
Terminals	:	Signals max. 1.5 mm ² , relay outputs max. 2.5 mm ²
Relays	:	2 x dry change-over contacts, each 250 VAC / 1 A / 250 VA or 100 VDC / 1 A / 100 W
Weight (net) approx.	:	450 g
Conformity and Standards	:	EMC 2004/108/EC: EN 61000-6-2 EN 61000-6-3 LV 2006/95/EC: EN 61010-1

6.3. Parameter-List

6.3.1. General

Description	Text	Min. Value	Max. Value	Default Value	Positions.	Characters	Serial Code
Unit Type	tYPE	0	4	0	1	0	00
Characteristic	CHAR	0	1	1	1	0	01
Brightness	briGht	0	4	0	1	0	02
Code	CodE	0	2	0	1	0	03
Frequency (Hz)	FrEqu	1	25000	1000	5	0	04
Display Value	diSPL	1	99999	1000	5	0	05
Decimal point	dPoint	0	5	3	1	0	06
Wait Time (sec)	L(Ait	1	999	10	3	1	07
Average Filter	FiLtEr	0	4	0	1	0	08
Display Format	diSFor	0	3	0	1	0	09
Frequency (Hz)	FrEqu	1	25000	100	5	0	10
Display Value	diSPL	1	999999	100	6	0	11
Wait Time (sec)	L(Ait	1	999	50	3	1	12
Average Filter	FiLtEr	0	4	0	1	0	13
Base	bASE	0	6	0	1	0	14
Start / Stop	StArt	0	2	1	1	0	15
Auto Reset	rESEt	0	1	0	1	0	16
Latch Function	LAteH	0	1	0	1	0	17
Count Mode	n)odE	0	5	3	1	0	18
Factor	FActor	1	99999	10000	5	4	19
Set Value	SEt	-199999	999999	0	86	0	20
Reset / Set	rESEt	0	3	3	1	0	21
Decimal point	dPoint	0	5	0	1	0	22
Measuring Time (sec)	tin)E	1	999999	1000	6	3	23
Display Value	diSPL	1	999999	1000	6	0	24
Decimal point	dPoint	0	5	0	1	0	25
Wait Time (s)	L(Ait	0	999	100	3	1	26

6.3.2. Linearization

Description	Text	Min. Value	Max. Value	Default Value	Positions.	Characters	Serial Code
L_Mode	LrnodE	0	2	0	1	0	D2
P1(x)	P01_H	-199999	999999	999999	86	0	A0
P1(y)	P01_Y	-199999	999999	999999	86	0	A1
P2(x)	P02_H	-199999	999999	999999	86	0	A2
P2(y)	P02_Y	-199999	999999	999999	86	0	A3
P3(x)	P03_H	-199999	999999	999999	86	0	A4
P3(y)	P03_Y	-199999	999999	999999	86	0	A5
P4(x)	P04_H	-199999	999999	999999	86	0	A6
P4(y)	P04_Y	-199999	999999	999999	86	0	A7
P5(x)	P05_H	-199999	999999	999999	86	0	A8
P5(y)	P05_Y	-199999	999999	999999	86	0	A9
P6(x)	P06_H	-199999	999999	999999	86	0	B0
P6(y)	P06_Y	-199999	999999	999999	86	0	B1
P7(x)	P07_H	-199999	999999	999999	86	0	B2
P7(y)	P07_Y	-199999	999999	999999	86	0	B3
P8(x)	P08_H	-199999	999999	999999	86	0	B4
P8(y)	P08_Y	-199999	999999	999999	86	0	B5
P9(x)	P09_H	-199999	999999	999999	86	0	B6
P9(y)	P09_Y	-199999	999999	999999	86	0	B7
P10(x)	P10_H	-199999	999999	999999	86	0	B8
P10(y)	P10_Y	-199999	999999	999999	86	0	B9
P11(x)	P11_H	-199999	999999	999999	86	0	C0
P11(y)	P11_Y	-199999	999999	999999	86	0	C1
P12(x)	P12_H	-199999	999999	999999	86	0	C2
P12(y)	P12_Y	-199999	999999	999999	86	0	C3
P13(x)	P13_H	-199999	999999	999999	86	0	C4
P13(y)	P13_Y	-199999	999999	999999	86	0	C5
P14(x)	P14_H	-199999	999999	999999	86	0	C6
P14(y)	P14_Y	-199999	999999	999999	86	0	C7
P15(x)	P15_H	-199999	999999	999999	86	0	C8
P15(y)	P15_Y	-199999	999999	999999	86	0	C9
P16(x)	P16_H	-199999	999999	999999	86	0	D0
P16(y)	P16_Y	-199999	999999	999999	86	0	D1

6.3.3. Preselections

Description	Text	Min. Value	Max. Value	Default Value	Positions.	Characters	Serial Code
Preselection Value 1	PrES1	-199999	999999	10000	86	0	27
Preselection Value 2	PrES2	-199999	999999	5000	86	0	28
Preselection Mode 1	CHAr1	0	5	0	1	0	29
Preselection Mode 2	CHAr2	0	5	0	1	0	30
Hysteresis 1	HYSt1	0	99999	0	5	0	31
Hysteresis 2	HYSt2	0	99999	0	5	0	32

6.3.4. Serial interface

Description	Text	Min. Value	Max. Value	Default Value	Positions.	Characters	Serial Code
Serial Timer (s)	S-tin)	0	9999	100	4	3	38
Serial Mode	S-n)od	0	2	0	1	0	39
Serial Code	S-CodE	100	120	101	3	0	40
Serial Unit Nr	S-Unit	0	99	11	2	0	90
Serial Format	S-Forn	0	9	0	1	0	92
Serial Baud Rate	S-bAUd	0	6	0	1	0	91

6.4. Commissioning Form

Date:	Software:	
Operator:	Serial number:	
<u>Basic settings:</u>	Unit Type: Brightness: Linearization Mode(*):	NPN /PNP: Code:
	Preselection Mode 1: Hysteresis 1:	Preselection Mode 2: Hysteresis 2:
	Serial Unit Number: Serial Baud:	Serial Format:

(*) Appears only with modes "RPM" and "Count"

<u>Operation Mode (Type)</u>		
RPM	Frequency (Hz): Decimal Point: Average Filter:	Display Value: Wait Time(sec):
Time	Display Format: Display Value: Average Filter:	Frequency (Hz): Wait Time (sec):
Timer	Base: Auto Reset:	Start/Stop: Latch Function:
Count	Count Mode: Set Value: Decimal Point:	Factor: Reset/Set:
Speed	Time (sec): Decimal Point:	Display Value: Wait Time (sec):

<u>Additional parameters:</u>		
	Preselection 1:	Preselection 2:
	Serial Timer (sec): Serial Code:	Serial Mode:

Linearization(*)

P1(x):	P1(y):	P9(x):	P9(y):
P2(x):	P2(y):	P10(x):	P10(y):
P3(x):	P3(y):	P11(x):	P11(y):
P4(x):	P4(y):	P12(x):	P12(y):
P5(x):	P5(y):	P13(x):	P13(y):
P6(x):	P6(y):	P14(x):	P14(y):
P7(x):	P7(y):	P15(x):	P15(y):
P8(x):	P8(y):	P16(x):	P16(y):

(*) Appears only with Modes "RPM" and "Count" if Linearization has been enabled

